## 12V 30W 1 Phase / DRP012V030W1A





### **Highlights & Features**

- Reliable design, with expected life of 10 years
- Compact, rugged design for ease of handling and installation
- Multiple connections to terminals allowed
- With Conformal Coating on PCBA (DRP012V030W1AZ)
- Class I, Div 2 Hazardous Locations (DRP012V030W1AY)
- Meets worldwide safety requirements
- RoHS Directive 2011/65/EU Compliant
- Worldwide AC input range without power de-rating
- Overvoltage / Overcurrent / Over Temperature Protections
- 150% Power Boost (steady state peak load) for 3 seconds

### **Safety Standards**









CB Certified for worldwide use

**Model Number:** DRP012V030W1A

**Unit Weight:** 0.20 kg

**Dimensions (L x W x D):** 100 x 32 x 100.6 mm

### **General Description**

The DRP012V030W1A□ is part of the CliQ series of DIN Rail power supplies from one of the world's largest power supply manufacturers and solution providers - Delta. This product provides an adjustable output capable of operating from input voltages at 85-264Vac, and a wide temperature range of -20°C to 75°C. With a rugged, compact plastic case design that meets shock and vibration requirements (in accordance to IEC60068-2-27 and IEC60068-2-6 respectively), and conformal-coated PCB assembly, this state of the art design is well suited to a broad variety of industrial applications worldwide.

### **Model Information**

## **CliQ DIN Rail Power Supply**

Model Number	Input Voltage Range	Output Voltage	Output Current
DRP012V030W1A□	85-264Vac (120-375Vdc)	12Vdc	2.5A

### **Model Numbering**

DRP	Р	012V	030W	1	Α	
DIN Rail	Power Supply	Output Voltage	Output Power	Single Phase	CliQ Series	Y - Plastic case with Class I, Div 2
						Z- Plastic case without Class I, Div 2



# 12V 30W 1 Phase / DRP012V030W1A

### **Specifications**

### **Input Ratings / Characteristics**

Nominal Input Voltage	100-240Vac
Input Voltage Range	85-264Vac
Nominal Input Frequency	50-60Hz
Input Frequency Range	47-63Hz
Nominal DC Input Voltage	125-250Vdc
DC Input Voltage Range	120-375Vdc
Input Current	< 0.70A @ 115Vac, < 0.42A @ 230Vac
Efficiency	> 85.0% @ 115Vac & 230Vac
Max Inrush Current	< 30A @ 115Vac, < 65A @ 230Vac
Power Factor	Conform to EN61000-3-2
Leakage Current	< 1mA @ 240Vac

### **Output Ratings / Characteristics**

Nominal Output Voltage	12Vdc
Output Voltage Tolerance	± 2% (initial set point tolerance)
Output Voltage Adjustment Range	11-14Vdc
Output Current	2.5A
Output Power	30W
Line Regulation	< 0.5% typ. (@ 85-264Vac input, 100% input)
Load Regulation	< 1% typ. (@ 85-264Vac input, 0-100% input)
Residual Ripple / PARD (20MHz)	< 100mVpp @ 25°C
Rise Time	< 20ms @ nominal input (100% load, 25°C)
Start-up Time	< 2500ms @ nominal input (100% load, 25°C)
Hold-up Time	> 22ms @ 115Vac, > 110ms @ 230Vac (100% load, 25°C)
Dynamic Response (Overshoot & Undershoot O/P Voltage)	± 5% @ 10-100% load
Start-up with Capacitive Loads	6,600µF Max

### **Mechanical**

Case Cover	Plastic
Dimensions (L x W x D)	100 x 32 x 100.6 mm
Unit Weight	0.20 kg
Indicator	Green LED (DC OK)
Cooling System	Convection
Terminal Input	M3.5 x 5 Pins (Rated 300V/15A)
Output	M3.5 x 5 Pins (Rated 300V/15A)
Wire Input	AWG 22-14
Output	AWG 22-14
Mounting Rail	Standard TS35 DIN Rail in accordance with EN60715



## 12V 30W 1 Phase / DRP012V030W1A

### **Environment**

Surrounding Air Temperature	Operating	-20°C to +75°C
	Storage	-25°C to +85°C
Power De-rating		> 50°C de-rate power by 2.5% / °C > 70°C de-rate power by 4% / °C
Operating Humidity		< 95% RH (Non-Condensing)
Operating Altitude		3,000 Meters
Shock Test (Non-Operating)		IEC60068-2-27, 30G (300m/S <sup>2</sup> ) for a duration of 18ms
Vibration (Non-Operating)		IEC60068-2-6, 10Hz to 150Hz @ 50m/S <sup>2</sup> (5G peak);
		90 min per axis for all X, Y, Z direction
Bump		IEC60068-2-29; 11ms / 10gn
Pollution Degree		2

### **Protections**

Overvoltage	16V +10% / -5%, SELV Output, Hicc-up Mode,
	Non-Latching (Auto-Recovery)
Overload / Overcurrent	> 150% of rated load current, Hicc-up Mode,
	Non-Latching (Auto-Recovery)
Over Temperature	< 80°C Surrounding Air Temperature @ 100% load,
	Non-Latching (Auto-Recovery)
Short Circuit	Hicc-up Mode, Non-Latching
	(Auto-Recovery when the fault is removed)
Degree of Protection	IPX0
Protection Against Shock	Class I without PE* connection

Reliability Data

MTBF	> 1,000,000 hrs. as per Telcordia SR-332
Expected Cap Life Time	10 years (115Vac & 230Vac, 50% load @ 40°C)



## 12V 30W 1 Phase / DRP012V030W1A

## **Safety Standards / Directives**

Electronic Equipment in Power Installations		EN50718 / IEC62103
Electrical Safety		TUV Bauart to EN60950-1, UL/cUL recognized to UL60950-1, CSA C22.2 No. 60950-1, CB scheme to IEC60950-1
Industrial Control Equipment		UL/cUL listed to UL508 and CSA C22.2 No. 107.1-01, CSA to CSA C22.2 No. 107.1-01
Hazardous Location / ATEX (For DRP012V030W1AY)		cCSAus to CSA C22.2 No.213-M1987, ANSI / ISA 12.12.01:2007 [Class I, Division 2, Group A,B,C,D T4 EN60079-0:2009, EN60079-15:2010 (
		Certificate No. EPS 12 ATEX 1 491 X For IEC60079-0, IEC60079-15
CE		In conformance with EMC Directive 2004/108/EC and Low Voltage Directive 2006/95/EC
		For DRP012V030W1AY:
		In conformance with Equipment for explosive atmospheres (ATEX) directive 94/9/EC
Material and Parts		RoHS Directive 2011/65/EU Compliant
Galvanic Isolation	Input to Output	4.0KVac
	Input to Ground	1.5KVac
	Output to Ground	1.5KVac

### **EMC**

EMC / Emissions		CISPR22, EN55022, EN55011, FCC Title 47: Class B	
Immunity to			
Electrostatic Discharge	EN61000-4-2	Level 4 Criteria A <sup>1)</sup>	
		Air Discharge: 15kV	
		Contact Discharge: 8kV	
Radiated Field	EN61000-4-3	Level 3 Criteria A <sup>1)</sup>	
		80MHz-1GHz, 10V/M with 1kHz tone / 80% modulation	
Electrical Fast Transient / Burst	EN61000-4-4	Level 3 Criteria A <sup>1)</sup>	
		2kV	
Surge	IEC6100-4-5	Level 3 Criteria A <sup>1)</sup>	
		Common Mode <sup>2</sup> : 2kV	
		Differential Mode <sup>3)</sup> : 1kV	
Conducted	EN61000-4-6	Level 3 Criteria A <sup>1)</sup>	
		150kHz-80MHz, 10Vrms	
Power Frequency Magnetic Fields	EN61000-4-8	Level 3 Criteria A <sup>1)</sup>	
		10A/Meter	
Voltage Dips	EN61000-4-11	Level 3 Criteria A <sup>1)</sup>	
		100% dip; 1 cycle (20ms); Self Recoverable	
Low Energy Pulse Test (Ring Wave)	IEC61000-4-12	Level 3 Criteria A <sup>1)</sup>	
		Common Mode <sup>2)</sup> : 2kV	
		Differential Mode <sup>3)</sup> : 1kV	


<sup>1)</sup> Criteria A: Normal performance within the specification limits




<sup>2)</sup> Asymmetrical: Common mode (Line to earth)3) Symmetrical: Differential mode (Line to line)

## 12V 30W 1 Phase / DRP012V030W1A

### **Block Diagram**



### **Device Description**




- 1) Input & Output terminal block connector
- 2) DC voltage adjustment potentiometer
- 3) DC OK control LED (Green)
- 4) Universal mounting rail system




## 12V 30W 1 Phase / DRP012V030W1A

#### **Dimensions**

L x W x D: 100 x 32 x 100.6 mm







### **Engineering Data**

#### **De-rating**




Fig. 1.1 De-rating for Vertical Mounting Orientation > 50°C de-rate power by 2.5% / °C, > 70°C de-rate power by 4% / °C


#### Note

- Power supply components may degrade, or be damaged, when the power supply is continuously used outside the shaded region, refer to the graph shown in Fig. 1.1.
- 2. If the output capacity is not reduced when the surrounding air temperature >50°C, the device will run into Over Temperature Protection. When activated, the output voltage will go into bouncing mode and will recover when the surrounding air temperature is lowered or the load is reduced as far as necessary to keep the device in working condition.
- If the device has to be mounted in any other orientation, please do not hesitate to contact info@deltapsu.com for more details.
- In order for the device to function in the manner intended, it is also necessary to keep a safety distance of 20mm with adjacent units while the device is in operation.
- Depending on the surrounding air temperature and output load delivered by the power supply, the device housing can be very hot!



## 12V 30W 1 Phase / DRP012V030W1A

### **Output De-rating VS. Input Voltage**




■No output power de-rating across the entire input voltage range

### **Assembly & Installation**

The power supply unit (PSU) can be mounted on 35mm DIN rails in accordance with EN60715. The device should be installed horizontally with input terminal blocks on the bottom.

Each device is delivered ready to install.

### **Mounting**





Snap on the DIN rail as shown on the left:

- 1. Pull the DIN rail's latch OUT.
- Tilt the unit upwards, hook the top end of onto the DIN rail and push downwards until stopped.
- 3. Position the bottom front end against the DIN
- 4. Push the unit's latch DIN rail IN to lock.

## **Dismounting**








## To uninstall:

- 1. Pull the unit's DIN rail latch OUT.
- 2. Tilt the bottom part of the unit out.
- 3. Push the unit up and pull out from the DIN rail.



## 12V 30W 1 Phase / DRP012V030W1A


### **Safety Instructions**



- ALWAYS switch mains of input power OFF before connecting and disconnecting the input voltage to the unit. If mains are not turned OFF, there is risk of explosion / severe damage.
- To guarantee sufficient convection cooling, keep a distance of 50mm above and below the device as well as a lateral distance of 20mm to other units.
- Note that the enclosure of the device can become very hot depending on the surrounding air temperature and load of the power supply. Risk of burns!
- Only plug in and unplug connectors when power is turned off!
- DO NOT insert any objects into the unit.
- Hazardous voltages may be present for up to 5 minutes after the input mains voltage is disconnected. Do not touch the unit during this time.
- The power supplies unit should be installed in minimum IP54 rated enclosure.
- The power supplies are built in units and must be installed in a cabinet or room (condensation free environment and indoor location) that is relatively free of conductive contaminants.

#### **Functions**

■ Graph illustrating the Start-up Time, Rise Time, and Hold-up Time



### **Start-up Time**

The time required for the output voltage to reach 90% of its set value, after the input voltage is applied.

### **Rise Time**

The time required for the output voltage to change from 10% to 90% of its set value.

### **Hold-up Time**


Hold up time is the time when the AC input collapses and output voltage retains regulation for a certain period of time. The time required for the output to reach 95% of its set value, after the input voltage is removed.



## 12V 30W 1 Phase / DRP012V030W1A


#### **Inrush Current**

Inrush current is the peak, instantaneous, input current measured and, occurs when the input voltage is first applied. For AC input voltages, the maximum peak value of inrush current will occur during the first half cycle of the applied AC voltage. This peak value decreases exponentially during subsequent cycles of AC voltage.




### **Surge Load**

It is the reserve power available constantly that allows reliable startup of loads with high inrush current. After the output has reached its steady state set value, the power supply can support surge loads of up to 150% of maximum rated load (Io Max), for a maximum duration of 3 seconds. The maximum allowed rate of load change is 0.1amps per microseconds, and the voltage can vary ±5% from the set value during the duration of the surge load.




## **Step Load Response**

The power supply output voltage will remains within ±5% of its steady state value, when subjected to a dynamic load from 10 to 100% of its rated current.



#### **Overload & Overcurrent Protections**


The power supply's Overload (OLP) and Over current (OCP) Protections will be activated when output current exceeds 150% of  $I_{\rm O}$  (Max load). In such occurrence, the  $V_{\rm O}$  will start to droop and once the power supply has reached its maximum power limit, the protection is activated and the power supply will go into "Hiccup mode" (Auto-Recovery). The power supply will recover once the fault condition of the OLP and OCP is removed and  $I_{\rm O}$  is back within the specifications.



Additionally, if the IO is <150% but >100% for a prolong period of time (depending on the load), the Over Temperature Protection (OTP) will be activated due to high temperature on critical components. The power supply will then go into "Hiccup mode" until the fault is removed.

### **Overvoltage Protection**

The power supply's overvoltage circuit will be activated when its internal feedback circuit fails. The output voltage shall not exceed its specifications defined on Page 3 under "Protections".





## 12V 30W 1 Phase / DRP012V030W1A□

### **Over Temperature Protection**

As mentioned above, the power supply also has Over Temperature Protection (OTP). This is activated when the overload condition persists for an extended duration and the output current is below the overload trigger point but >100% load. In the event of a higher operating condition at 100% load, the power supply will run into OTP when the surrounding air temperature is >80°C. When activated, the output voltage will go into bouncing mode until the operating surrounding air temperature drops to 50°C or output capacity is reduced as recommended in the derating graph.

#### **Short Circuit Protection**

The power supply's output OLP/OCP function also provides protection against short circuits. When a short circuit is applied, the output current will operate in "Hiccup mode", as shown in the illustration in the OLP/OCP section on this page. The power supply will return to normal operation after the short circuit is removed.

### **Operating Mode**




Fig. 2.1 Redundancy / Parallel Operation Connection Diagram

\*V<sub>drop</sub> will vary from 0.40V to 0.60V (Typical 0.45V) depending on the load current and surrounding air temperature.

### Redundancy Operation

In order to ensure proper redundancy operation for the power supply unit (PSU), ensure that the output voltage difference between the two units is kept at 0.20~0.25V for 12V supplies. Follow simple steps given below to verify:

### Step 1.

Measure output voltage of PSU 1 and PSU 2. If PSU 1 is the master unit, then Vo of PSU 1 must be higher than PSU 2.

In order to set the output voltage, connect the power supply to 50% load and set the PSU 1 and PSU 2 output voltage.

#### Step 2

Connect the right DRR module, 20A as per the system requirement to the power supply units PSU 1 and PSU 2 at  $V_{in}$  1 &  $V_{in}$  2 respectively.

#### Step 3.

Connect the system load from  $V_{out}$ . Please note that output voltage  $V_{out}$  from DRR module will be =  $V_O$  (output voltage of power supply) -  $V_{drop}^*$  (in DRR module).

#### **■** Parallel Operation

These DRR modules can also be used for Parallel function in order to increase the output power by N+1 (e.g. 2.5A + 2.5A = 5A or 2.5A + 2.5A = 7.5A) or current sharing, and thus increasing the power supply and system reliability. Though the DRP012V030W1AZ is not designed for current sharing, a good current sharing between two power supplies can be achieved by following simple steps as below (Refer to Fig. 2.1 for the Connection Diagram).

#### Step 1.

Set output load condition for both supplies at 50% and measure the output voltages.

#### Step 2.

Adjust output voltages to the same level or within ±25mV difference.

#### Step 3

Connect PSU 1 and PSU 2 with the DRR-20A module and measure at  $V_{in}$  1 &  $V_{in}$  2 to verify the voltage difference. Ensure the voltages are within  $\pm 25 \text{mV}$ .

### Step 4.

Output voltage from DRR module  $V_{out}$  will be =  $V_{O}$  (output voltage of power supply) –  $V_{drop}^*$  (in DRR module).

\*V<sub>drop</sub> will vary from 0.40V to 0.60V (Typical 0.45V) depending on the load current and surrounding air temperature.



## 12V 30W 1 Phase / DRP012V030W1A

### **Others**

### **Delta RoHS Compliant**



#### Restriction of the usage of hazardous substances

The European directive 2011/65/EC limits the maximum impurity level of homogeneous materials such as lead, mercury, cadmium, chrome, polybrominated flame retardants PBB and PBDE for the use in electrical and electronic equipment. RoHS is the abbreviation for "Restriction of the use of certain hazardous substances in electrical and electronic equipment".

This product conforms to this standard.

### **Conformal Coating**



### **The Protective Coating Technology**

Delta Electronics Group has designed the perfect dipping technique which penetrates everywhere including under device, and prevents leakage. The conformal coating dipping can be applied to PCBs or circuit board. The coating preserves the performance of precision electronic primarily by preventing ionizable contaminants such as salt from reaching circuit nodes, where the material slumps around sharp edges. This can be a problem especially in highly conversing atmosphere.

